



Question 3:

On the pump jack sign, the derrick elevation appears to be water jetted derrick, we were having a problem on attaching the stainless wire mesh to it, is expanded metal welded to the derrick section then powder coated a possibility?

Answer:

A perforated metal square, similar to **McNICHOLS®** Perforated Metal Square, Carbon Steel, Cold Rolled, 16 Gauge (.0598" Thick), 3/4" Square on 1" Straight Centers, 56% Open Area

ITEM: [16980016](#) **SIZE(S):** 48" x 24"; 48" x 120" is preferred to the expanded metal.

Welding to the derrick section and then powder coating is acceptable.

This addendum consists of two (2) pages.


CHERRY/SEE/REAMES ARCHITECTS, PC

By 

Tina M. Reames, President

APPROVED:

City of Lovington

By  _____

James Williams, City Manager